ELECT. WING, BSNL Corporate Office Room No. 8, IR Hall, Eastern Court, Janpath,

New Delhi -110001

Tel: 23736527 Fax: 23322398



No. 3-2-5/ EW/ VEP-1/ 2007

Dated :- 19.12.11.

To

All Pr. Chief Engineers / Sr. Chief Engineers / Chief Engineers (Elect.) B.S.N.L.

Subject:- Phase - out of KCG 554 and KCG 562 compressor models

Consequent upon the submission of M/s Emerson Climate Technologies (India) Limited regarding phasing out of KCG554 and KCG 562 compressor models, I am directed to intimate that the following changes in the bill of material of High sensible air cooled AC package units are hereby approved by the competent authority as per the following details:

Compressor phased out model	Equivalent model
KCG554HAE - D 512	CR53KQM – TFD – 2XX
KCG562HAE - D 512	CR62KQM – TFD – 2XX

The performance of the above new compressor models shall be watched and in case of adverse performance this office shall be informed for further action.

(J. K. Dua) AGM (Elect.) I

Copy to :-

- 1. M/s Fedders Lloyd Corporation Limited, C 4, Phase II, Noida 201305
- 2. M/s Sidwal Refrigeration Industries Limited, 108-A, Madangir, New Delhi 110062